

## Kongres Container

# Lead-acid battery cabinet panel



## Overview

---

Will a 50 Ah battery fit in a control panel?

Some control panel models are listed for battery replacement reference only. For 2 bay international applications only, 50 Ah batteries will fit in the cabinet. \* Batteries smaller than those listed are normally mounted in the product cabinet \*\* 25 Ah capacity was effective as of 7/2005.

Who approves Battery Cabinet 2081-9280?

\* Battery cabinet 2081-9280 has been approved by the California State Fire Marshal (CSFM) pursuant to Section 13144.1 of the California Health and Safety Code. See CSFM Listing 7315-0026:144 for allowable values and/or conditions concerning material presented in this document.

What is the fuse size for a battery cabinet?

Internal battery cabinet output fuse is 80 A for battery protection. In-line battery fuse requirement: To protect the output conductors, install a line fuse rated properly to the load current in the battery plus side of each output pair. Wire per applicable local code.

## Lead-acid battery cabinet panel

---

## Contact Us

---

For catalog requests, pricing, or partnerships, please visit:  
<https://drugiswiatowykongrespolakow.pl>